

# Detailed Latest Test Results



# SEAWARD

ELECTRONIC LTD.

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/01/2005 To: 24/05/2007

**Client:** A N Other      **Site:** A N Other      **Location:** GARAGE

Asset ID: 001      Description: Jet Wash      User: M.GANCARZ      Test Instrument: T37-0005

Test Type	Date	Result	Unit	Status
Visual	09/08/2006			Pass
Insulation	09/08/2006	>99.99	MOhm	Pass
Leakage	09/08/2006	<0.1	mA	Pass
Load	09/08/2006	<0.05	kVA	Information

Overall: Pass

Asset ID: 002      Description: Hand Buffer      User: M.GANCARZ      Test Instrument: T37-0005

Test Type	Date	Result	Unit	Status
Visual	09/08/2006			Pass
Insulation	09/08/2006	>99.99	MOhm	Pass
Leakage	09/08/2006	<0.1	mA	Pass
Load	09/08/2006	<0.05	kVA	Information

Overall: Pass

Total Tests: 2